

AUGUST 2007

BOEING INTEGRATED DEFENSE SYSTEMS
ENVIRONMENTAL ANALYSIS LABORATORY

STATION: Plant 2 (P2) 2-122, Wastewater Pretreatment Plant
PERMIT/DA No. #: 7811

SITE #: A4023-I

Page 1

SAMPLE DATE	FLOW gal/day	pH, min	pH, max	Cadmium mg/L	Chromium mg/L	Copper mg/L	Lead mg/L	Nickel mg/L	Zinc mg/L	
DAILY LIMIT-> (mg/L)	30000	5.5	12	0.11	2.75	3	0.69	2.5	2.61	
08/01/07	16162	10.9	11	0.004	0.58	0.14	<0.051	0.13	0.065	Batch #P2-07-19
08/07/07	8052	9	9	<0.0040	0.38	0.11	<0.051	0.049	0.054	Batch #P2-07-20
08/10/07	8040	11.6	11.7	<0.0020	0.36	0.13	<0.027	0.11	0.075	Batch #P2-07-21
08/16/07	8071	11.1	11.4	0.003	0.46	0.086	<0.027	0.16	0.026	Batch #P2-07-22
08/17/07	8101	9	10.5	<0.0040	0.51	0.1	<0.051	0.23	0.031	Batch #P2-07-23
08/22/07	8039	8.8	11.2	<0.0040	0.3	0.088	<0.051	1.3	0.093	Batch #P2-07-24
08/29/07	8051	8.8	8.9	<0.0020	0.37	0.082	<0.027	0.77	0.085	Batch #P2-07-25
08/31/07	8092	8.3	8.6	<0.0040	0.24	0.098	<0.051	0.76	0.076	Batch #P2-07-26
Min Value	8039	8.3		<0.0040	0.24	0.082	<0.051	0.049	0.026	
Min Date		8/31/2007								
Max Value	16162		11.7	0.004	0.58	0.14	<0.051	1.3	0.093	
Max Date	8/1/2007		8/10/2007							
Average	9076	9.7	10.3	<0.0040	0.4	0.104	<0.051	0.439	0.063	
Monthly Flow	72608									

Analytical Reference: Methods for Analysis of Water and Waste, EPA - 600/4-79-020.

I certify under penalty of law this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations. I further certify that all data requiring a laboratory analysis were analyzed by a Washington State Department of Ecology accredited laboratory for each parameter tested.

 9/11/07
Signature of Principal Executive or Authorized Agent Date